FLAME-SPREAD RATING

FRTW products are used in many interior applications, such as millwork and panelling, where the code requirements for flame spread are most restrictive. The Canadian building codes also permit the use of fire-retardant treated lumber and plywood for roof and floor trusses, beams, interior roof decks, and for interior load-bearing and non-load bearing partitions.

FRTW is suitable for indoor applications where the humidity is not expected to exceed 60 percent for long periods of time. FRTW should be protected from excessive moisture and weather during transit, storage, and erection. While some wetting might be expected during installation, frequent wetting or ponding is unacceptable. In general, FRTW requires more care in installation than would normally be considered sufficient good practice for non-FRTW products.

FRTW, as defined and specified in the NBC, must have a flame-spread rating of not more than 25. It therefore qualifies as an interior finish for any application since the most restrictive flame-spread rating is 25. FRTW must be identified by a label (Figure 1, below) from an independent testing laboratory or certification organization which indicates that the necessary tests were performed and production controls maintained. This performance test can be carried out only by an accredited third-party testing agency.

For many wood species, and particularly plywood and lumber in sizes common to light-frame construction, FRTW treatment results in chemical retentions high enough to obtain a flame-spread rating of 25 or less. It should be noted that the chemicals will not usually penetrate the entire wood member, as refusal will usually occur when the chemicals have penetrated approximately 13 mm from the outer surface of the product.

The actual flame-spread rating of treated lumber or plywood depends on the fire-retardant chemicals used and the amount of chemicals retained in the wood, which depends on several factors, including wood species.

Commonly used chemicals are proprietary mixtures which are free of halogens, sulphates, ammonium phosphate and formaldehyde. These provide superior performance characteristics over previous formulations and lower corrosivity to metal fasteners. These water-soluble chemicals are effective in reducing flame spread, and through careful proportioning succeed in reducing smoke development and afterglow.

To dispel any myths that may still exist, it should be understood that the fire-retardant treatment does not make the wood noncombustible. This idea stems from certain earlier versions of building codes which equated a 25 surface flame-spread rating to noncombustibility. The NBC uses a different method to determine "noncombustibility" (CAN/ULC-S135, *Standard Method of Test for Determination of Degrees of Combustibility of Building Materials Using an Oxygen Consumption Calorimeter (Cone Calorimeter)*), and FRTW does not meet the noncombustibility criteria under that method.

The use of a fire-retardant treatment does not prevent ignition or charring. The rate of burn through fire-retardant treated wood is approximately the same as that for untreated wood, even though ignition is more difficult and the rate at which flame travels across its surface (flame-spread rating) has been reduced.

CLASSIFIED AS TO ACCORDANCE WITH			CLASSIFIED AS					
FOR COMMENTARY O RATING SEE ULC LIS UNDER GUIDE NO. 4	T OF EQUIPMEN	T AND MATE	RIALS, VOL. II,	FOR COMMENTA RATING SEE ULC UNDER GUIDE N	LIST OF E			
MATERIAL DETAILS	FLAME SPREAD FSC75 (GWL)	SMOKE	FUEL		FLAM			
SOUTHERN YELLOW	20 (15)	10		DETAILS	FSC	75(GWL)	DEVELOPED	CONTRIBUTE
DOUGLAS FIR*	15 (15)	0	0					
REDWOOD*	10 (5)	5	0	SOUTHERN YELLOW PINE	20	(15)	10	0
WHITE PINE"	10 (5)	20	0	1				
HEMLOCK/FIR*	15 (5)	20	0	DOUGLAS FIR .	15	(15)	15	5
WESTERN RED CEDAR"	20 (10)	5-35	15	REDWOOD .	10	(5)	10	5
MAPLE	55-80 (30-40)	100-130	70-35					
RED DAK	40 (20-30)	35-80	15-25	" IN TEST OF 30 M	N. DURATIO	N. FLAME S	SPREAD NOT ON	ER EQUIVALEN
SPRUCE PINE FIR				OF 25 AND NO EV	DENCE OF S	SIGNIFICAN	IT PROGRESSIV	E COMBUSTION
INCISED*	20 (15)	15	10-25					
"IN TEST OF 30 MIN. DUI 25 AND NO EVIDENCE OF ALL SPECIES MAY BE SU	SIGNIFICANT PRO	GRESSIVE COM	BUSTION			I	Interior	Гуре
•				Fire-F	Fire-Retardant Treated Wood			

Figure 1. Sample labels/markings from one independent certification organization for fire-retardant-treated lumber and plywood.